

TENDER NO **AIIP/REPL/006/OU**

SUBJECT **SUPPLY OF ODORIZING UNIT AT COTONOU , BENIN OF WEST AFRICA**

CORRIGENDUM NO **01** **DATED** **06-04-2023**

This has reference to the subject tender. The corrigendum to the subject tender is hereby issued. All participating bidders are requested to note the changes in respect of the subject tender.

S No	Tender Clause No	Page No.	Tender Conditions	Addition
1	Clause 7 (F) of IFB Bid Due Date & Time	05	06.04.23 till 15:00 HRS IST. Bids should be submitted by E-mail as per clause no. 6.3 of IFB	10.04.2023 at 15:00 HRS IST by E-mail as per clause no. 6.3 of IFB
2	Clause 7 (J) of IFB Technical Bid Opening Due date & Time	06	06.04.23 till 15:30 HRS IST	10.04.2023 at 15:30 HRS IST
3	Pre-Bid Queries		Replies to Pre-Bid Queries	Pre-Bid queries and their replies are attached as per Annexure-1

It is advised that the above may please be taken in consideration while submitting your offer. Please also note that this communication forms an integral part of the tender document and a duly acknowledged copy of the same is to be submitted along with technical bid.

All other terms and conditions of above referred tender remain un-altered.

Resonance Energy Pvt. Ltd.

ANNEXURE-1

QUERIES RAISED DURING PRE-BID MEETING BY BIDDERS AND REPLY / CLARIFICATION TO BIDDERS BY OWNER/CONSULTANT

Tender No.: AIIP/REPL/006/OU		Date / Time of Pre- Bid Meeting: 31/03/23	
Venue : VC		Date of Pre-bid Clarifications: 05/04/23, Rev 0.0	
Tender Description :- SUPPLY OF ODORIZING UNIT AT COTONOU, BENIN OF WEST AFRICA			
Sr. No.	Tender Clause No. / Annexures	Bidders Comments/Queries	SIPI-Benin/REPL Reply
	Technical Queries	Clarification Needed/BIDDERS CONCERN	SIPI-Benin/REPL Reply
1	TECHNICAL SPECIFICATION clause 1.4 DATA SHEET- ODORIZING UNIT	We have been providing the ATEX & PESO for the approved model which is as per the CGD industry norms & standard. SIL 2 certification is required for a highly critical operations. The OD skid isn't involved in any such operations . Also with SIL 2 certified components are 4 time more costlier than the ATEX & PESO approved components model. Kindly allow us to use the ATEX & PESO approved devices	Accepted
2	TECHNICAL SPECIFICATION clause 1.3 (b) DATA SHEET- ODORIZING UNIT	The tender mentions that 230 V power supply shall be available at the ECU unit and also the power backup will be provided, when the said supply is available adding solar system will be redundant and will be just an extra addition to the costing with no added value. If the incase M/s:SIPI still decided to move ahead with the Solar panel it should be installed in safe area along with the ECU near the control room M/s:SIPI need to confirm the power source that will be provided so that accordingly the system design for ECU can be taken in to consideration for costing purpose.	Power Supply will be made available by SIPI-Benin.(Bidder need to submit offer without solar panel.)
3	As per SOR Sr. No 1.2	Please clarify scope of per day supervision charges . We understand expenses like To - and - fro travelling, Visa charges Lodging and boarding, local transport etc. shall be taken care by customer. Please clarify.	Flight tickets (Economy Class), VISA, lodging & boarding and local convenience, fooding shall be in the scope of SIPI BENIN and provided as per the existing policy.
4	DATA SHEET - ODORISING UNIT Page 49 of 69 (Clause No.1.4)	All components such as verometer/ solenoid valve/ electronic control unit shall be suitable for hazardous area. Ex-proof and ATEX approved.	Bidder understanding is correct
5	TECHNICAL SPECIFICATION AND SCOPE OF WORK Page 48 (SECTION IV)	Pls. confirm whether communication modem shall be required for receiving operation log details at the control room.	SIPI BENIN will provide
6	TERMS OF PAYMENTS Page 43 (Clause No.6)	30% payment shall be in Advance. Balance 65% shall be paid after third party inspection before dispatch against LC.	Tender condition prevails
7	TERMS OF PAYMENTS Page 43 (Clause No.6)	You are requested to provide the draft of LC for review and the name of bank for checking the feasibility.	Draft LC shall be provided after bidder's evaluation.
8	CONTRACT-CUM-EQUIPMNET PERFORMANCE BANK GUARANTEE (CPBG) Page-44 . Clause No.11.1	5% shall be maintained as retention and shall be released after successful commissioning.	Refer Clause no. 11.6 of SCC of tender document
9	SCHEDULE OF RATE	If No. of mandays increases more than 5 days due to non readiness of site conditions e.g injection point on commissioned pipeline, odorant filling, availability of 4-20 ma flowsignal from meter etc. Additional charges as per unit rate shall be applicable.	If there is delay due to non-readiness of site conditions or due to scope of work covered for client ,then only additional charge shall be applicable.
10	SCHEDULE OF RATE	Please clarify if the client will provide the visa, transportation and accomodation for the commissioning team.	As per SN. 03