

TENDER NO : AIP/REPL/003/STPL

SUBJECT : TENDER FOR LAYING & CONSTRUCTION OF 12” NB X 30 KM AND 6” NB X 6 KM (APPROX.) SUB TRANSMISSION STEEL PIPELINE NETWORK & ASSOCIATED WORKS FROM MARIA GLETA TO GLO-DJIBE INDUSTRIAL ZONE, BENIN.

DATED : 23/08/2023

This has reference to the subject tender. The corrigendum to the subject tender is hereby issued. All participating bidders are requested to note the changes in respect of the subject tender.

S No	Tender Clause No	Page No.	Tender Conditions	Amendment/ Addition/ Modification/ Deletion
<u>COMMERCIAL</u>				
1	IFB (Clause 7.5)	5 of 70 Commercial Volume I of II	23.08.2023 till 18:00 HRS (WAT) (Bids should be submitted by E-mail as per clause no. 6.3 of IFB	29.08.2023 till 18:00 HRS (WAT) (Bids should be submitted by E-mail as per clause no. 6.3 of IFB
2	IFB (Clause 7.9)	5 of 70 Commercial Volume I of II	24.08.2023 till 10:30 HRS (WAT)	30.08.2023 till 10:30 HRS (WAT)
3	IFB (Clause 18.0)	Commercial Volume I of II	Reply to Pre Bid Queries	Additional bidder queries and their replies are attached as per Annexure-1.
<u>TECHNCIAL</u>				
3	16.0 (Description of Items)	42 of 466 Technical Vol II of II	<u>Existing</u> Note (D) Supply of all assorted CS pipes, Valves, IJs, flanges, fittings & Flow/ barred tees etc. shall be paid by separate item mentioned in SOR 23. Supply of LR Bend are included in above mentioned pipeline laying rate. No separate payment shall be paid.	<u>To be read as</u> Note (D) Supply of all assorted CS pipes, Valves, IJs, flanges, fittings & Flow/ barred tees etc. shall be paid by separate item mentioned in SOR 22. Supply of 4”NB and above LR Bend are not in the scope of contractor. It will be supplied by the Owner.

4	16.0 (Description of Items)	42 of 466 Technical Vol II of II	<p>Existing Supply & Installation of LR Bend (R = 3D), as per specification wherever required depending on site condition. Supply of all fittings, elbow, etc. Is in Contractor's scope and shall be as per 3.2 certification</p>	<p>To be read as Supply of 4"NB and above LR Bend, fittings are not in the scope of contractor. It will be supplied by the Owner.</p>
4	SOR	-	<p>Existing SOR Item No.11.0 Installation of all Fitting & Valves In Bypass Line For Isolation Valves.</p>	<p>To Refer SOR – Revision 01 Existing SOR is replaced with Schedule of Rates – Revision 01 (can be downloaded through Resonance Energy website www.energyworld.biz)</p> <p>To be read as Item No.11.0 Installation And Testing Of All Fitting & Valves In Bypass Line For Isolation Valves. Note: The above SOR is only for installation & testing of bypass line. The installation of main line Isolation valve will be paid separately as per SOR 14.2 & 14.3”</p> <p>Addition Item 14.3 - Valve,Ball,API6D,FB BW 300#, 6 INCH</p> <p><i>Bidder to submit offer in Revised Schedule of Rates - Revision 01 format only Else bid shall be rejected</i></p>

It is advised that the above may please be taken in consideration while submitting your offer. Please also note that this communication forms an integral part of the tender document and a duly acknowledged copy of the same is to be submitted along with technical bid.

All other terms and conditions of above referred tender remain un-altered.

Resonance Energy Pvt. Ltd.



ADDITIONAL REPLY TO PRE BID QUERIES - ANNEXURE 1

FOR

LAYING & CONSTRUCTION OF 12" NB X 30 KM AND 6" NB X 6 KM (APPROX.) SUB TRANSMISSION STEEL PIPELINE NETWORK & ASSOCIATED WORKS FROM MARIA GLETA TO GLO-DJIBE INDUSTRIAL ZONE, BENIN.

Tender No.: AIIP/REPL/003/STPL

Client : SIPI -Benin

Consultant : REPL

Date / Time of Pre- Bid Meeting: 09/08/2023 @ 10:30 Hrs (WAT)

Date of Pre-bid Clarifications: 23.08.2023



Sr. No.	Tender Clause No. / Annexures	Bidder's Query/Clarification	SIPI-Benin/REPL Reply
COMMERCIAL			
1	IFB Clause 7.5, 7.9	We request timeline extension to submit our bid.	Ref Corrigendum#02, S.No 1 and 2.
2	Commercial Vol I of II	Based on the discussion with our International team, there is 18% VAT. We shall be opening the branch office in Benin and shall bill to client from local office. Kindly let us know whether the VAT will be applicable if local billing is done.	VAT will be exempted for this project; however, other local charges & cess or duties will be in contractor's scope. It is recommended to mention all considered taxes, charges, duties, cess in separate table while submitting commercial proposal.
3	Commercial Vol I of II	Kindly confirm the statutory auditor if he should be an external auditor from the client or an auditor appointed internally by the client	The verification and certification of tender documents pertaining to BQC criteria and as per Clause 29.1 of IFB shall be carried out by Statutory Auditor of the Bidder, none shall be borne by the client.
TECHNICAL			
1	Technical Vol II of II	Entire Project P&ID is not provided. Kindly provide us the entire P&ID, Hookup drawings with existing pipeline, launcher and receivers P&ID.	P&ID will be provided during execution of 12"NB pipeline. However, Construction of Dispatch and Receiving terminal is not in the scope of this tender. Please refer alignment sheets and standard drawing of SV station i.e REPL/CGD/STD/CSP-045 of Technical Vol II of II.
2	Technical Vol II of II	We understand that there is only 1 SV Station and kindly provide us the P&ID for the same.	There are 8 SV stations of 12"NB and one in 6"NB pipeline
3	Technical Vol II of II	It is not clear whether EGP / Caliper Pigging is a part of contractor's scope or not.	EGP/Caliper pigging is not in the contractors scope. Please go through the clause no.15 MAINTENANCE DURING DEFECTS LIABILITY PERIOD in Technical vol.II of II for detail scope.
4	Technical Vol II of II	It is not clear from your reply whether intelligent pigging is a part of scope or not, but in clause no 15 (page 39 of 466 of technical document) it is showing requirement of intelligent pigging in DLP time. So we understand that this is not a part of bidders scope. Kindly clarify	Intelligent pigging is not in the contractors scope. Please go through the clause no.15 MAINTENANCE DURING DEFECTS LIABILITY PERIOD in Technical vol.II of II for detail scope.
5	Technical Vol II of II (SOR)	Kindly clarify us on the difference between the two, items 4.1 and 4.2 of the SOR.-	Item No. 4.1 is for carrying out HDD for the Profile as per approved drawings and specification in tender documents and for Item No. 4.2 is for Major river Crossing by HDD method.